

Procurement 42022-49

Fence and Gate

Questions Feb 6.2024

Q: Fence Specs: I did not see listed the specs to which the fence should be constructed to? Are these available somewhere?

A: We would prefer 6' chain link with 3 rows of barbed wire on angle brackets on top of that to mirror existing fence around the retaining pond, silver in color / galvanized.

Q: Gate Operator Specs: I did not see listed the specs to for the Gate operator on the 30'W Double Gate, and the single passage gate? Are these available somewhere?

A: The automatic gate for the entrance way will be a single gate 30 ft wide and should retract to the south to avoid hitting the pond or pond fence.

Passage gate at the front should be mag strike, key pad / fob release.

All other gates will be manual open manual swing.

Q: Wage Scale: Will this job have a wage scale associated with the labor? Where can I find this information?

A: Davis Bacon will apply

A: Deadline to submit bids has been extended to March 1 2024